



Product specification form

The purpose is to get information to be able to configure the product

Vapor quality sensor





Specify your application:

- DX evaporator control
- Overfeed evaporator control/pump circulation
- Compressor protection
- Other - pls. specify

What is your pipe size

Which refrigerant do you use:

Select product type:

	installation	Pipe size							Refrigerants
		Inch mm	¼" 6	½" 13	1" 25	2" 50	4" 100	8" 200	
<input type="checkbox"/>  Angel rod	Elbow		6-25 mm						CO2 HFC/HFO
<input type="checkbox"/>  In line	Straight horizontal or vertical			25-65 mm					CO2 HFC/HFO Ammonia HC
<input type="checkbox"/>  Strainer house	Elbow			20-300 mm					Ammonia HFC/HFO
<input type="checkbox"/>  Rod style	In an elbow after a horizontal pipe				50-200 mm				CO2 HFC/HFO Ammonia HC

Select product output

- Analog signal only 4-20 mA
- Direct valve control. Type of valve:

Your contact information